

Jackson County School District #91 (Butte Falls)

Comprehensive Radon Testing Results

- The EPA's recommended action level for radon is **4 pCi/L** and will require mitigation by the district, followed by retesting.
- 25 spike tests were conducted to ensure the integrity of the testing process and all spike tests passed satisfactorily.

Site Name	Building Name	Room Description (per floor plan)	Kit serial #	Date Sampled	Type of test	Results (pCi/L)
Butte Falls SD #91	District Office	Supt Office	5154668	11/22/2021	Detector kit	0.9
Butte Falls SD #91	District Office	Tech Office	5154653	11/22/2021	Detector kit	0.8
Butte Falls SD #91	District Office	Maintenance Office	5154854	11/22/2021	Detector kit	0.9
Butte Falls SD #91	District Office	Break Room	5154761	11/22/2021	Detector kit	0.7
Butte Falls SD #91	District Office	Receptionist Office	5154828	11/22/2021	Detector kit	0.7
Butte Falls SD #91	District Office	Board Room	5154873	11/22/2021	Detector kit	0.9
Butte Falls SD #91	District Office	Health Clinic	5154816	11/22/2021	Detector kit	0.8
Butte Falls SD #91	High School	Health Classroom	5087752	11/22/2021	Detector kit	0.7
Butte Falls SD #91	High School	English Classroom	5072247	11/22/2021	Detector kit	2.6
Butte Falls SD #91	High School	Science Classroom	5072413	11/22/2021	Detector kit	0.7
Butte Falls SD #91	High School	Science Storage	5072136	11/22/2021	Detector kit	0.6
Butte Falls SD #91	High School	Computer Lab	5154826	11/22/2021	Detector kit	1.1
Butte Falls SD #91	High School	Social Studies Classroom	5154736	11/22/2021	Detector kit	1.0
Butte Falls SD #91	High School	Small Conference Room	5154906	11/22/2021	Detector kit	1.4
Butte Falls SD #91	High School	SPED Resource Room	5154912	11/22/2021	Detector kit	1.5
Butte Falls SD #91	High School	Math Classroom	5154914	11/22/2021	Detector kit	4.7
Butte Falls SD #91	High School	Math Classroom	5072378	11/22/2021	Retest	3.6
Butte Falls SD #91	High School	Office Health Room	5133574	12/13/2021	Detector kit	2.6
Butte Falls SD #91	High School	Main Office	5072107	11/22/2021	Detector kit	1.0
Butte Falls SD #91	High School	Student Store/Storage	5154835	11/22/2021	Detector kit	2.0
Butte Falls SD #91	High School	Counselor/AD Office	5071836	11/22/2021	Detector kit	0.4
Butte Falls SD #91	High School	Principal Office	5154769	11/22/2021	Detector kit	1.1
Butte Falls SD #91	High School	Staff Lunch Room	5154766	11/22/2021	Detector kit	1.7
Butte Falls SD #91	Secondary Manufacturing	Tech Arts - Metals	5072274	11/22/2021	Detector kit	<0.3
Butte Falls SD #91	Secondary Manufacturing	Tech Arts - Wood	5072503	11/22/2021	Detector kit	<0.3
Butte Falls SD #91	Secondary Gymnasium	Main Gymnasium	5072524	11/22/2021	Detector kit	1.1
Butte Falls SD #91	Secondary Gymnasium	Main Gymnasium	5154710	11/22/2021	Detector kit	1.3

Jackson County School District #91 (Butte Falls) Comprehensive Radon Testing Results

Site Name	Building Name	Room Description (per floor plan)	Kit serial #	Date Sampled	Type of test	Results (pCi/L)
Butte Falls SD #91	Secondary Gymnasium	Main Gymnasium	5072126	11/22/2021	Detector kit	0.8
Butte Falls SD #91	Secondary Gymnasium	Main Gymnasium	5072061	11/22/2021	Detector kit	1.2
Butte Falls SD #91	Secondary Gymnasium	Main Gymnasium	5087797	11/22/2021	Detector kit	1.5
Butte Falls SD #91	Secondary Gymnasium	Main Gymnasium	5124718	11/22/2021	Detector kit	1.1
Butte Falls SD #91	Secondary Gymnasium	Weight Room	5154734	11/22/2021	Detector kit	<0.3
Butte Falls SD #91	Secondary Gymnasium	Concession Stand	5154929	11/22/2021	Detector kit	1.4
Butte Falls SD #91	Elementary Main	Room 1 - SPED	5154672	11/22/2021	Detector kit	1.2
Butte Falls SD #91	Elementary Main	Room 2 - Gr 3	5154866	11/22/2021	Detector kit	1.4
Butte Falls SD #91	Elementary Main	Room 3 - Gr 1	5154728	11/22/2021	Detector kit	1.8
Butte Falls SD #91	Elementary Main	Room 4 - Kindergarten	5154682	11/22/2021	Detector kit	1.6
Butte Falls SD #91	Elementary Main	Room 8 - Gr 4	5154867	11/22/2021	Detector kit	1.6
Butte Falls SD #91	Elementary Main	Room 7 - Gr 2	5154862	11/22/2021	Detector kit	1.3
Butte Falls SD #91	Elementary Main	Room 6 - Gr 5	5154673	11/22/2021	Detector kit	1.4
Butte Falls SD #91	Elementary Main	Room 5 - ERC	5154898	11/22/2021	Detector kit	1.5
Butte Falls SD #91	Elementary Main	Library	5154778	11/22/2021	Detector kit	1.6
Butte Falls SD #91	Elementary Main	Office Health Room	5154777	11/22/2021	Detector kit	1.7
Butte Falls SD #91	Elementary Main	Principal Office	5154680	11/22/2021	Detector kit	1.5
Butte Falls SD #91	Elementary Main	Office Counter	5154648	11/22/2021	Detector kit	1.7
Butte Falls SD #91	Elementary Main	Office Counter	5154737	11/22/2021	Detector kit	1.9
Butte Falls SD #91	Elementary Annex	Room 9 - Gr 6/7	5154755	11/22/2021	Detector kit	3.4
Butte Falls SD #91	Elementary Annex	Room 10 - Gr 6/7	5154836	11/22/2021	Detector kit	4.2
Butte Falls SD #91	Elementary Annex	Room 10 - Gr 6/7	5087777	12/13/2021	Retest	2.9
Butte Falls SD #91	Elementary Gym/Cafeteria	Stage	5154851	11/22/2021	Detector kit	0.7
Butte Falls SD #91	Elementary Gym/Cafeteria	Gymnasium	5154848	11/22/2021	Detector kit	0.6
Butte Falls SD #91	Elementary Gym/Cafeteria	Gymnasium	5154911	11/22/2021	Detector kit	1.2
Butte Falls SD #91	Elementary Gym/Cafeteria	Kitchen	5154645	11/22/2021	Detector kit	0.8
Butte Falls SD #91	Elementary Gym/Cafeteria	Kitchen	5154927	11/22/2021	Detector kit	0.8
Butte Falls SD #91	Bus/Maintenance Barn	Bus Barn	5154900	11/22/2021	Detector kit	0.4
Butte Falls SD #91	NRC - Maker Space House	Basement	5154850	11/22/2021	Detector kit	2.1
Butte Falls SD #91	NRC - Maker Space House	Storage	5154751	11/22/2021	Detector kit	1.9

Jackson County School District #91 (Butte Falls) Comprehensive Radon Testing Results

Site Name	Building Name	Room Description (per floor plan)	Kit serial #	Date Sampled	Type of test	Results (pCi/L)
Butte Falls SD #91	NRC - Maker Space House	Center Room	5154693	11/22/2021	Detector kit	1.7
Butte Falls SD #91	NRC - Maker Space House	Classroom	5154724	11/22/2021	Detector kit	1.6
Butte Falls SD #91	NRC - Culinary Arts House	Classroom	5154752	11/22/2021	Detector kit	1.5
Butte Falls SD #91	NRC - Caretakers House	Main Living Room	5154688	11/22/2021	Detector kit	1.6
Butte Falls SD #91	NRC - Main Operations	West Room	5154864	11/22/2021	Detector kit	2.2
Butte Falls SD #91	NRC - Main Operations	West Room	5154847	11/22/2021	Detector kit	2.1
Butte Falls SD #91	NRC - Main Operations	West Room	5154727	11/22/2021	Detector kit	1.6
Butte Falls SD #91	NRC - Main Operations	East Room	5154897	11/22/2021	Detector kit	1.9
Butte Falls SD #91	NRC - Main Operations	East Room	5154878	11/22/2021	Detector kit	1.7
Butte Falls SD #91	NRC - Main Operations	East Room	5154877	11/22/2021	Detector kit	1.5
Butte Falls SD #91	NRC - Multi Purpose Building	Feed/Plant Storage	5154799	11/22/2021	Detector kit	1.3
Butte Falls SD #91	WORK EAST	East Workroom	5154764	11/22/2021	Detector kit	2.0
Butte Falls SD #91	WORK EAST DUP	East Workroom	5154846	11/22/2021	Detector kit	2.1
Butte Falls SD #91	WORK WEST	West Workroom	5154791	11/22/2021	Detector kit	2.2
Butte Falls SD #91	NRC - Higher Ed House	Main Living Room	5154881	11/22/2021	Detector kit	1.3
Butte Falls SD #91	NRC - Higher Ed House	Main Living Room	5154646	11/22/2021	Detector kit	1.6